

**Rome-Floyd Fire Marshal's
Office
409 E 12th Street
Rome, GA 30161
706-236-4510**

Fire and Life Safety Checklist

Name of Facility _____ Date _____

Address _____

Emergency Contact Name and Phone # _____

	Yes	No	N/A	Remarks Section
Street Address Posted (4" min.)				
Fire walls or partitions have no penetrations				
Exit are Marked & Signs Lit				
Emergency Lighting Operable				
Exit Doors are Clear & Unlocked				
Electrical Room Clear & Accessible				
No Extension Cords (Long term use)				
All electrical switches and outlets are covered				
No open empty spaces in panel box				
Compressed gas cylinders are secured				
Portable Fire Extinguishers Maintained & Tagged (min. 5lb. ABC)(serviced yearly)				
Gas fired water heater has min. of 3' clearance all around from combustibles				
Storage- not blocking exits, panel boxes, etc.				
Sprinkler System Maintained & Tagged (serviced yearly)				
Hood System Maintained & Tagged – (Every 6 Months)				

A Knox Box will be required for all new businesses with a fire protection system or existing businesses that add a new fire protection system before a business license can be issued. It is the responsibility of the applicant to install the Knox Box per the city/county ordinance. The box may be ordered online at www.knoxbox.com. Fulfilling the requirements of this form does not ensure that a business license will be issued. This form is meant to help new business owners with the Rome-Floyd Fire Marshal's Office inspection process and is not an all inclusive form.